


STRATHMORE GATE EAST AT LAKE ST GEORGE HOMEOWNERS' ASSOCIATION, INC.

HURRICANE STORM PANEL SPECIFICATIONS



The following specifications are required for the installation of hurricane storm panel systems:

1. Removable panels to be fabricated of minimum .040 corrugated aluminum, 24 GA galvanized steel or clear polycarbonate.
2. Panel widths to be approximately 12 inches.
3. Wall mounted panel tracks are to be installed above and below window and/or sliding glass door openings providing for vertical installations. Panel tracks are to be painted the color of the exterior building wall.
4. Panel tracks are to be fastened to wall with non-corrosive 2 ½" Tapcon masonry fasteners every 12-18".

RULES AND REGULATIONS GOVERNING USE OF HURRICANE STORM PANEL SYSTEMS

1. Removable, stackable panels are to be stored within the unit or its storage area and are not to be stored visible from the exterior of the unit.
2. Panels may be installed no sooner than 48 hours in advance of a pending storm and are to be removed no later than 72 hours after the storm threat has passed.
3. Panels are not to be used for privacy or security purposes.
4. Any damage to the exterior of the unit caused by the installation or use of the panels shall be repaired by the unit owner as soon as practically possible and in no event beyond 14 days from the date of such damage.